



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx CML 17.0125X

Issue No: 0

Certificate history:

Issue No. 0 (2017-11-02)

Status: **Current**

Page 1 of 3

Date of Issue: **2017-11-02**

Applicant: **Pulsar Process Measurement**
Cardinal Building
Enigma Commercial Centre
Sandy's Road
Malvern
WR14 1JJ
United Kingdom

Equipment: **mmWAVE-is**

Optional accessory:

Type of Protection: **Intrinsic Safety**

Marking:

Ex ia IIC T4 Ga

Ex ia IIIC T135°C Da

-40°C to +80°C

*Approved for issue on behalf of the IECEx
Certification Body:*

D R Stubbings MIET

Position:

Technical Director

*Signature:
(for printed version)*

Date:

2017-11-02

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Certification Management Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No: IECEX CML 17.0125X Issue No: 0

Date of Issue: **2017-11-02** Page 2 of 3

Manufacturer: **Pulsar Process Measurement**
Cardinal Building
Enigma Commercial Centre
Sandy's Road
Malvern
WR14 1JJ
United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements
Edition:6.0

IEC 60079-11 : 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/CML/ExTR17.0152/00](#)

Quality Assessment Report:

[GB/SIR/QAR06.0030/07](#)



IECEX Certificate of Conformity

Certificate No: IECEx CML 17.0125X

Issue No: 0

Date of Issue: 2017-11-02

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The mmWAVE-is is a DC powered level measurement sensor utilising radar technology.

The sensor is housed in a non-metallic enclosure with integral five core cable which connects to control equipment located in the safe area providing power and data communication. The enclosure incorporates a threaded cap which allows the equipment to be mounted on a suitable bracket or flange.

See Annex for full details

SPECIFIC CONDITIONS OF USE: YES as shown below:

See Annex for details

Annex:

[IECEX CML 17.0125X Annex Iss 0.pdf](#)

Annexe to: IECEx CML 17.0125X Issue 0
Applicant: Pulsar Process Measurement
Apparatus: mmWAVE-is



Product Description

The mmWAVE-is is a DC powered level measurement sensor utilising radar technology. The sensor is housed in a non-metallic enclosure with integral five core cable which connects to control equipment located in the safe area providing power and data communication. The enclosure incorporates a threaded cap which allows the equipment to be mounted on a suitable bracket or flange.

Intrinsic safety is achieved by connecting to the non-hazardous area via intrinsically safe interface devices, and by encapsulation of the electronics and sensor.

The equipment has the following safety description:

Power Port		Signal Port		RX port		TX port	
Ui	= 28V	Ui	= 10V	Ui	= 10V	Ui	= 10V
Ii	= 120mA	Ii	= 200mA	Ii	= 200mA	Ii	= 200mA
Pi	= 0.83W	Pi	= 0.5W	Pi	= 0.5W	Pi	= 0.5W
Ci	= 5nF	Ci	= 0	Ci	= 0	Ci	= 0
Li	= 0	Li	= 0	Li	= 0	Li	= 0
				Uo	= 6.51V	Uo	= 6.51V
				Io	= 208mA	Io	= 208mA

Conditions of manufacture

- i. Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.

Conditions of Certification

- i. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. This is particularly important if the equipment is installed in a zone 0 location. In addition, the equipment shall only be cleaned with a damp cloth
- ii. The equipment must be routinely inspected to avoid the build up of dust layers when installed in a Zones 20, 21, or 22.

Unit 1, Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
 E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642



- iii. The equipment must only be connected to resistive intrinsically safe sources with minimum resistances as follows
- Power connection $R \geq 234\Omega$
 - Signal connection $R \geq 50\Omega$
 - TX connection $R \geq 50\Omega$
 - RX connection $R \geq 50\Omega$
- iv. When installing the equipment, the installer shall consider the length of integral cable attached to the equipment, in addition to any externally installed cable. The integral cable shall be considered to have parameters of 200pF/m , and $1\mu\text{H/m}$ or $30\mu\text{H}/\Omega$